



Certificate of Conformity

Certificate Number: CN-PV-230602

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Shanghai SIGEN New Energy Technology Co., Ltd. No. 175 Weizhan Road, Lingang New Area, China(Shanghai) Pilot Free Trade Zone, Shanghai, P.R.China
Product:	PV Grid inverter & Hybrid Inverter
Ratings & Principle Characteristics:	See appendix of Certificate of Conformity
Model:	SigenStor EC x TP, Sigen Hybrid x TP, SigenStor AC x TP, Sigen PV Max x TP (x: 5.0, 6.0, 8.0, 10.0, 12.0, 15.0, 17.0, 20.0, 25.0)
Brand Name<s>:	 SIGENERGY
Product Complies with:	UTE C 15-712-1:2013 DIN V VDE V 0126-1-1:2013 Enedis-PRO-RES_10E version 5 Compliant with VFR 2019
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2 nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
Test Report No.<s>:	230705143GZU-001, 30 Oct. 2023 230705143GZU-002, 30 Oct. 2023

Additional information in Appendix.



Signature

Certification Manager: Grady Ye

Date: 01 November 2023



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.