

Type Certificate

Applicant SMA Solar Technology AG

Sonnenallee 1 34266 Niestetal Germany

Type of product	Grid connected photovoltaic Storage Inverter	SUNNY TRIPOWER STORAGE X	Sunny Island X		
		STPSxx-20	SIxx-20		
Technical data	Max. apparent power	50 kVA			
	Nominal output AC voltage:	400 V (3~+N+PE)			
	Nominal frequency	50 Hz			
	Max. active power P _{Emax} / Max. active power peak P ₆₀₀ :	(for details see Supplement of Certificate on p.2)			
Firmware version	(main processor) 3.01.xx.R Note: "xx" can be any number, changes on this position indicate no certification relevant modifications				
Validated model	Model file	STPSx_10_RMS_Lib_V6016B02.dll (Inverter control dll)			
	Identification number (MD5)	2bad809cd6beca8c316fafe86e2cea96			

Connection rule VDE-AR-N 4110:2023-09 — Technical requirements for the connection and operation of customer

installations to the medium voltage network (TCR medium voltage) [1]

Applicable standards / Technical guidelines: FGW TR 3 Rev. 25 [2], FGW TR 4 Rev. 09 [3], FGW TR 8 Rev. 09 [4]

directives

The power generating units, stated in the certificate, were tested and certified according to the technical guidelines referenced to the grid connection regulation. The electrical characteristics fulfil the requirements of the grid connection regulation:

- Quasi-steady-state operation
- Dynamic network stability (reactive current characteristic according to TCR medium voltage & TCR high voltage)
- Active power output and network security management
- · Active power adjustment as a function of the grid frequency
- Protection technology and protection settings on generating unit level.
- Power quality

Restrictions or deviations: see supplement of certificate

The manufacturer has provided proof of certification of the quality management system of his production facility in accordance with ISO 9001

The certificate contains the following information:

- technical data of the power generating unit, the auxiliary equipment used and the software version used;
- schematic structure of the power generating units;
- summarized information on the properties of the power generating unit.

The certificate is comprised of 64 pages (including Annex of 63 pages).

Report number: 22TH0488

Certificate number: U24-1127_0
Issued: 2024-11-27

Certification Program: NSOP-0032-DEU-ZE-V10
Valid until: 2029-11-26



Accreditation

Accredited certification body by Deutsche Akkreditierungsstelle GmbH (DAkkS) according to ISO/IEC 17065. The accreditation is valid only for the scope listed in the annex of the accreditation certificate D-ZE-12024-01-00. The Deutsche Akkreditierungsstelle GmbH (DAkkS) is signatory of the multilateral arrangements of EA, ILAC and IAF for mutual recognition.

Certification body

Georg LORITZ
Lab Supervisor Energy Systems

Without the written consent of Bureau Veritas Consumer Products Services Germany GmbH excerpts of this certificate of conformity shall not be reproduced

Bureau Veritas Consumer Products Services Germany GmbH www.bureauveritas.de/unsere-services/produktzertifizierung

Businesspark A96 86842 Tuerkheim



Supplement of certificate (U24-1127_0)

Type of product

Technical data

Grid connected photovoltaic	STPSxx-20		Slxx-20	
Storage Inverter	STPS50-20	STPS30-20	SI50-20	SI30-20
Nominal active output power 1)	50 kW	30 kW	50 kW	30 kW
Rated / Max. apparent power	50 kVA	30 kVA	50 kVA	30 kVA
Nominal voltage	400 V (3 ⁻ +N+PE)			
Nominal frequency	50 Hz			
Max. active power P _{Emax} / Max. active power peak P ₆₀₀ ^{2), 3):}	50,38	30,23	50,38 ¹⁾	30,23 1)

Note:

- The nominal active output power P_n is just a nominal value defined by manufacturer. Due to spot testing the tests marked were not conducted. The stated results were transferred from the type STPS50-20 and STPS30-20 to SI50-20 and SI30-20 respectively according to measurements of test 4.1.1, FGW TR 3 [2].
- The P_{Emax} is the highest 10-min mean of the active power of a power generating unit defined according to VDE-AR-N 4110:2018 [1]. The P600 is the maximum active power peak of the overall system (averaging period 10 min) defined according to FGW TR 3 Rev. 25 [2].
- The stated measurement results were determined according to test 4.1.1, FGW TR 3 Rev. 25 [2].

Report number: 22TH0488

Certificate number: U24-1127_0
Issued: 2024-11-27



Certification Program: NSOP-0032-DEU-ZE-V10

alid until: 2029-11-26

Accreditation



Accredited certification body by Deutsche Akkreditierungsstelle GmbH (DAkkS) according to ISO/IEC 17065. The accreditation is valid only for the scope listed in the annex of the accreditation certificate D-ZE-12024-01-00. The Deutsche Akkreditierungsstelle GmbH (DAkkS) is signatory of the multilateral arrangements of EA, ILAC and IAF for mutual recognition.

Without the written consent of Bureau Veritas Consumer Products Services Germany GmbH excerpts of this certificate of conformity shall not be reproduced.



Restrictions, deviations or notes on usage

1. The PGUs in the series do not provide test terminals for on-site testing. For necessary on-site testing, a separate test terminal must be installed additionally.

Report number: 22TH0488
Certificate number: U24-1127_0
Issued: 2024-11-27



Certification Program: NSOP-0032-DEU-ZE-V10

2029-11-26

Accreditation



Accredited certification body by Deutsche Akkreditierungsstelle GmbH (DAkkS) according to ISO/IEC 17065. The accreditation is valid only for the scope listed in the annex of the accreditation certificate D-ZE-12024-01-00. The Deutsche Akkreditierungsstelle GmbH (DAkkS) is signatory of the multilateral arrangements of EA, ILAC and IAF for mutual recognition.

Without the written consent of Bureau Veritas Consumer Products Services Germany GmbH excerpts of this certificate of conformity shall not be reproduced.