



Product Service

Compliance Document

No. D 114228 0004 Rev. 01

Holder of Certificate: **JA Solar Technology Co., Ltd.**
 No. 123 Xinxing Road
 055550 Ningjin County, Hebei Province
 PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062401603-01

Date, 2024-08-29

(Zhulin Zhang)



Product Service

Compliance Document

No. D 114228 0004 Rev. 01

Model(s):

JAM66D45-xxx/LB, xxx = 580 to 620 in steps of 5
 JAM72D40-xxx/LB, xxx = 560 to 615 in steps of 5
 JAM60D40-xxx/LB, xxx = 485 to 510 in steps of 5
 JAM54D40-xxx/LB, xxx = 420 to 460 in steps of 5
 JAM72D42-xxx/LB, xxx = 590 to 650 in steps of 5
 JAM66D42-xxx/MB, xxx = 540 to 595 in steps of 5
 JAM60D42-xxx/LB, xxx = 500 to 540 in steps of 5
 JAM54D42-xxx/LB, xxx = 455 to 475 in steps of 5
 JAM78D30-xxx/MB, xxx = 580 to 605 in steps of 5
 JAM72D30-xxx/MB, xxx = 505 to 560 in steps of 5
 JAM66D30-xxx/MB, xxx = 465 to 505 in steps of 5
 JAM60D30-xxx/MB, xxx = 435 to 460 in steps of 5
 JAM54D30-xxx/MB, xxx = 390 to 415 in steps of 5
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790
Test Condition Severity:	Method A
Remark:	Modules listed above comply with the requirements of being non-sensitive to PID-d (No delaminations of category A, B or C).

**Tested
according to:**

IEC TS 62804-1-1:2020